


# Reactor core meltdown and radioactivity release during the Fukushima Daiichi accident

12/06/27 Ebisawa T

1. Introduction
2. Structure of “Mark I” Boiling Water Reactor
3. Available Core Cooling Systems  
in the Fukushima Accident after SBO
4. How the Reactor Cores Now ?




25m掘削  
原子炉を  
設置



浸水経路になったと考えられる。 【添付 7-1】

なお、建屋内部の水配管等からの溢水で重要機器が損傷しないように必要な箇所には溢水対策を講じており、隣接するエリアからの浸水防止のため堰や水密扉の設置などを行っている。しかし、今般のようにルーバなど上部から浸水し、その浸水箇所の水密性が高い場合（非常用D/G室など）、浸水が滞留するケースも見られた。

Fig. 1 Turbine Building Attacked Tsunami




## (2) 津波による設備被害

14時46分に地震が発生し、その地震動の到達によって各プラントでは地震動を検

## 2 Structure of MARK I BWR

Fig. 2 Reactor Building






Fig. 3 Structure of Reactor Syster

- 1 Core
- 5 Fuel storage pool
- 8 Reactor pressure vessel
- 9 Biological shield
- 10 Concrete shield
- 11 Free standing steel dry well
- 13 Concrete embedment
- 27 Spent Fuel
- 30 Steam pipe
- 31 Control rods
- 32 Blow down line


PCV Radiation Monitor

When the radio activities in the core flow into PCV, the monitor detects the radiations.

Basement concrete of  
about 7 meters thickness

# BWR/6

## REACTOR ASSEMBLY



GENERAL  ELECTRIC




Fig. 4 BWR Reactor

1. VENT AND HEAD SPRAY
2. STEAM DRYER LIFTING LUG
3. STEAM DRYER ASSEMBLY
4. STEAM OUTLET
5. CORE SPRAY INLET
6. STEAM SEPARATOR ASSEMBLY
7. FEEDWATER INLET
8. FEEDWATER SPARGER
9. LOW PRESSURE COOLANT INJECTION INLET
10. CORE SPRAY LINE
11. CORE SPRAY SPARGER
12. TOP GUIDE
13. JET PUMP ASSEMBLY
14. CORE SHROUD
15. FUEL ASSEMBLIES
16. CONTROL BLADE
17. CORE PLATE
18. JET PUMP / RECIRCULATION WATER INLET
19. RECIRCULATION WATER OUTLET
20. VESSEL SUPPORT SKIRT
21. SHIELD WALL
22. CONTROL ROD DRIVES

Boiling Water Reactor (BWR)  
Reactor Pressure Vessel (RPV) Diagram 0.58





Fig. 5 BWR Cooling System

### 3. Available Core Cooling Systems in the Fukushima Accident after SBO

- 3-1 The 1 st Reactor has two Isolation Condensers (IC)
- 3-2 The 2 nd and 3 rd Reactor have A Reactor Core Isolation Cooling (RCIC) System.
- 3-3 Fire Engines were used to cool the Molten Cores.

Fig. 5 Isolation Condenser(IC)  
非常用復水器(IC)

資料 II -17



# Fig 6 Reactor Core Isolation System (RCIC)




Fig. 7 The Cooling of the molten Core using the Fire Engine

代替注水について

Water filler was installed  
in June of 2010

The Cooling Water from The Fire Engine was injected to the Reactor along the Red Line.




Fig. 8 Simulation results by TEPCO on the PCV pressure.





図 3-3 2号機 格納容器圧力変化



otes: [1] Nuclear event levels are triggered by particular events regardless of radiation dosage. Partially melted rods at Fukushima warrants Level 5. Levels 1, 2 and 3 have specific radiation dosage limits. Source: International Atomic Energy Agency (IAEA), Nuclear Incident Event Scale (INES)

[2] Chernobyl Source: B. Medvedev, JPRS Report on Soviet Union Economic Affairs Chernobyl Notebook, 1989.

[3] Fukushima events from numerous sources. Listed on wikipedia page for Fukushima I Nuclear Accident. Measurement data: TEPCO. Mar. 16th

# The accident sequence of the 1st Reactor

In the 1st Reactor, any cooling system did not operate after SBO, so that the event sequences were very simple. IC were not available by the valve problems .

- 1) 11/03/11/14:46 : Earth Quake occurred : Reactor scammed
- 2) 11/15:35 : Power station was attacked by Tsunami
- 3) 11/15:42 : Station Black Out (SBO)
- 4) 11/18:30 : Reactor water level went down to TAF(Top of Active Fuel)
- 5) 11/20:30 : Core melting started
- 6) 11/23:00 : Core collapsed
- 7) 12/01:00 : Pressure of PVC rose to 0.52 Mpa gauge
- 8) 12/02:45 : The pressures of the Reactor and PCV became the same  
9) Reactor penetration failure occurred until this time.
- 10) 12/04:00 : Molten core fell down on the concrete floor of PCV
- 11) 12/05:40 : A fire engine supplied cooling water to the reactor vessel
- 12) 12/14:30 : PCV(S/C) Vent
- 13) 12/15:36 : Hydrogen explosion

# The accident sequence of The 2nd Reactor

- 1) 11/03/11/14:46 : Earth Quake occurred : Reactor scrammed
- 2) 11/15:35 : Tsunami occurred
- 3) 11/15:39 : RCIC (Reactor Core Isolation Cooling system)operated
- 4) 14/10:00 : RCIC lost the cooling capability
- 5) 14/16:20 : Water level went down to TAF(Top of Active Fuel)
- 6) 14/18:20 : Water level went down to BAF(Base of Active Fuel)
- 7) 14/21:00 : The pressure of Reactor and PCV become same value
- 8) 14/23:35—15/7:25 : High pressure of 0.65(Mpa g) kept
- 9) 15/07:25—11:25 : Pressure changed quickly : PCV broken
- 10) 15/11:25—13:00 : Much steam was generated in the reactor
- 11) 15/13:30 : Reactor vessel broken in the base
- 12) 15/15:25 : Peak value of PCV radiation monitor  
This show that much X-133 were released
- 14)




Fig.8 Present status of the 1st reactor molten core by simulations of (TPCO).

The core of the 1<sup>st</sup> Reactor fell down on the floor of the PCV.

The core concrete reaction was occurred after the falling down.

Anyone doesn't know the molten core broke the base plate of the PCV or not.





Fig. 9 TEPCO estimates that 60 % of the molten core fell down on the base of PCV in the maximum.

## 2. 解析結果 1号機



- ドレンサンプピット壁面の侵食が進行するにつれ、侵食面は円形に近づくと推定される。
- このため、実際の侵食停止位置における断面形状は左図と右図の間にいると推定される。

## 2. 解析条件②

### ● 解析条件

- 落下炉心割合はMAAP解析から得られた最大の値を保守的に仮定(1号機: 100%、2号機: 57%、3号機: 63%)
- 崩壊熱ソースはORIGEN2を使用。揮発性FPの放出による崩壊熱の減損(20%)を仮定
- 燃料デブリ落下時点までにPLRメカシールからのリーク水がペデスタル部に十分溜まっていた場合(2, 3号機)は燃料デブリが一部粒子化すると仮定  
※粒子化しなかった燃料デブリによる侵食を評価
- 燃料デブリはペデスタル床からスリットを通してドライウェル床まで流出。ペデスタル内にある2つ(機器／床)のドレンサンプへも燃料デブリが堆積すると仮定

